

○1号機 アラームタイパー主要打ち出し (抜粋)

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
14	46	46	400	D564*	SEISMIC TRIP C	TRIP
14	46	46	410	D534	REACTOR SCRM A	TRIP
14	46	58	420	D563	SEISMIC TRIP B	TRIP
14	46	58	430	D535	REACTOR SCRM B	TRIP
1446	A538	REM		BYPS	ON	
1446	B500	CONT ROD DRFT ALRM			ON	
14	47	00	020	D562	SEISMIC TRIP A	TRIP
14	47	00	030	D565	SEISMIC TRIP D	TRIP
1447	C020	SUPPRESSION	LEVEL		-40.8< -20.0 MM	
1447	A523	APRM	DOWN SCAL		TRBL	
1447	A539	RWM	ROD BLOK		ON	
1447	A553	ALL CR FULL IN			ON	
1447	G002	GENERATR VOLT			18.56> 18.50 KV	
1447	C000	CONT ROD SYST FLOW			OVR FLW	
1447	C020	SUPPRESSION	LEVEL		16.0 MM NORMAL RETURN	
14	47	09	140	D520	REAC WTR LEVL A	LOW
1447	C004	REACTOR WATR LEVEL			516< 800 MM	
14	47	09	150	D521	REAC WTR LEVL B	LOW
1447	E004	SWCHGEAR BUS 1A			7217> 7200 V	
14	47	10	910	D523	REAC WTR LEVL D	LOW
1447	C020	SUPPRESSION	LEVEL		21.6> 20.0 MM	
14	47	10	910	D522	REAC WTR LEVL C	LOW
1447	A549	LOW POWR ALRM POINT			UNDER	
14	47	20	620	D522	REAC WTR LEVL C	NORM
1447	D622	PCIS ISO IN TRIP			ON	
14	47	20	620	D523	REAC WTR LEVL D	NORM

地震による自動スクラム

全制御棒全挿入