

1447	B033	CAMS	H2	MONI	S/C	LOW	RSN		
14	47	57	070	D590	DIES GEN CB	1D-1	ON		
1447	B034	CAMS	O2	MONI	S/C	LOW	RSN		
14	47	57	140	D681	6.9KV BUS VLT	1D	LOS	OFF	
1447	G000	GENERATR	GROS	LOAD	383.0	MW	NORMAL	RETURN	
14	47	58	920	D589	DIES GEN CB	1C-1	ON		
1447	G001	GENERATR	GROS	VAR	9.0	<	10.0	MVAR	
14	47	58	970	D680	6.9KV BUS VLT	1C	LOS	OFF	
1447	G002	GENERATR	VOLT	LOW	RSN				
14	48	00	220	D660	PLR A	LOCOUT	RY	ACT	ON
1447	C007	REAC	PMP	TOTL	FLOW	LOW	RSN		
14	48	13	280	D576	TURBINE	VIB	OVER	NORM	

DG(B) 遮断器投入

DG(A) 遮断器投入

1452	A567	RX	MODE	SW	REFUEL	OFF		
1452	C020	SUPPRESSION	LEVL	16.8	MM	NORMAL	RETURN	
1452	C020	SUPPRESSION	LEVL	37.6	>	20.0	MM	
1452	B526	ISO-CON	VLV	B	OPN	ON		
1452	B525	ISO-CON	VLV	A	OPN	ON		
1452	C020	SUPPRESSION	LEVL	14.0	MM	NORMAL	RETURN	
1452	A516	SRM	DET	POS	IN			
1452	C020	SUPPRESSION	LEVL	35.2	>	20.0	MM	

非常用復水器作動