

1448	B031	CAMS	H2 MONI	D/W	0.2 %	NORMAL RETURN
1448	B032	CAMS	O2 MONI	D/W	18.5 %	NORMAL RETURN
1448	B033	CAMS	H2 MONI	S/C	0.1 %	NAL RETURN
1448	B034	CAMS	O2 MONI	S/C	18.3 %	NORMAL RETURN
1448	C020	SUPPRESSION	LEVEL		26.8>	20.0 MM
1448	S213	HP TURB EXH	PRS		UKN	B.V
1448	S215	CRV/CIV HOOD	PRS		UKN	B.V
1448	C020	SUPPRESSION	LEVEL		3.2 MM	NORMAL RETURN
1448	C020	SUPPRESSION	LEVEL		25.2>	20.0 MM
1448	C020	SUPPRESSION	LEVEL		2.0 MM	NORMAL RETURN
1448	TOSWAY	L-STN	01			FAIL
1448	TOSWAY					FAIL
1448	C020	SUPPRESSION	LEVEL		31.2>	20.0 MM
1448	C020	SUPPRESSION	LEVEL		9.6 MM	NORMAL RETURN
1449	A099	HOTWELL	MMHO	A	0.07	MS/C NORMAL RETURN
1449	C030	D/W PRES	(W/R)		107	KPAA NORMAL RETURN
1449	C020	SUPPRESSION	LEVEL		36.8>	20.0 MM
1449	E015	COND PMP PRES	C		LOW	RSN
1449	C020	SUPPRESSION	LEVEL		18.4 MM	NORMAL RETURN
1449	C020	SUPPRESSION	LEVEL		25.6>	20.0 MM
1449	F051	HOTWELL	LEVEL	A		UP RSN
1449	F052	HOTWELL	LEVEL	B		UP RSN
1449	C020	SUPPRESSION	LEVEL		14.8 MM	NORMAL RETURN
1449	C020	SUPPRESSION	LEVEL		29.6>	20.0 MM
1449	S236	HOTWELL	LEVEL			UKN B.V
1449	F064	IA PRES			0.620	MPA NORMAL RETURN
1449	C020	SUPPRESSION	LEVEL		10.4 MM	NORMAL RETURN
1449	C020	SUPPRESSION	LEVEL		22.4>	20.0 MM
1449	B022	STACK RAD MONI	H/R		-1.37	MS/H NORMAL RETURN
1449	F002	CONDEMIN OUTL	PRES		0.10	MPA NORMAL RETURN
1449	C029	EMERCON	LEVEL	B	80.3 %	NORMAL RETURN
1450	B530	D/W O2 MON	RANG (W)		OFF	
1450	F004	HP TURB	EXH	C	0.010	MPA NORMAL RETURN
1450	F007	MOIS SEP	STM	A	0.010	MPA NORMAL RETURN
1450	F008	MOIS SEP	STM	B	0.013	MPA NORMAL RETURN
1450	F009	MOIS SEP	STM	C	0.008	MPA NORMAL RETURN
1450	A553	ALL CR	FULL IN		OFF	
1450	A553	ALL CR	FULL IN		ON	
1450	F010	MOIS SEP	STM	D	0.012	MPA NORMAL RETURN
1450	F003	HP TURB	EXH	A	0.008	MPA NORMAL RETURN
1450	C020	SUPPRESSION	LEVEL		9.6 MM	NORMAL RETURN
1450	S573	CMS TROUBLE			ON	
1450	C020	SUPPRESSION	LEVEL		34.0>	20.0 MM
1450	C020	SUPPRESSION	LEVEL		8.4 MM	NORMAL RETURN
1450	C020	SUPPRESSION	LEVEL		28.4>	20.0 MM
1451	C020	SUPPRESSION	LEVEL		17.2 MM	NORMAL RETURN
1451	C020	SUPPRESSION	LEVEL		22.0>	20.0 MM
1451	C003	REACTOR	PRES		6.90>	6.90 MPA
1451	C020	SUPPRESSION	LEVEL		14.0 MM	NORMAL RETURN
1451	C020	SUPPRESSION	LEVEL		30.0>	20.0 MM
1452	A519	IRM	DET	POS		OUT
1452	A520	IRM	DOWN	SCAL		TWBL
1452	A565	RK MODE	SW	STAT		ON
1452	A564	RK MODE	SW	OPER		OFF
1452	A567	RK MODE	SW	REFUEL		ON
1452	A565	RK MODE	SW	STAT		OFF
1452	A566	RK MODE	SW	SHT DOWN		ON
1452	A567	RK MODE	SW	REFUEL		OFF
1452	C020	SUPPRESSION	LEVEL		16.8 MM	NORMAL RETURN
1452	C020	SUPPRESSION	LEVEL		27.6>	20.0 MM
1452	B526	ISO-CON	VLV	B	OPN	ON
1452	B525	ISO-CON	VLV	A	OPN	ON
1452	C020	SUPPRESSION	LEVEL		14.0 MM	NORMAL RETURN
1452	A516	SRM	DET	POS		IN
1452	C020	SUPPRESSION	LEVEL		35.2>	20.0 MM
1452	A516	SRM	DET	POS		OUT NORMAL RETURN
1452	C020	SUPPRESSION	LEVEL		4.4 MM	NORMAL RETURN
1452	C020	SUPPRESSION	LEVEL		34.4>	20.0 MM
1453	C020	SUPPRESSION	LEVEL		16.0 MM	NORMAL RETURN
1453	C020	SUPPRESSION	LEVEL		30.8>	20.0 MM

→ 原子炉モードスイッチ「運転」→「停止」

→ I C (A) (B) 「自動起動」